



{In Archive} Fw: 081007 PTP EPA violation.pdf

Aaron Setran to: David Albright, Rich Campbell

10/09/2008 08:11 AM

From: Aaron Setran/R9/USEPA/US
To: David Albright/R9/USEPA/US@EPA, Rich Campbell/R9/USEPA/US@EPA,
Archive: This message is being viewed in an archive.

Re: Pineview explanation why all wastewater was shunted to upper field.

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

----- Forwarded by Aaron Setran/R9/USEPA/US on 10/09/2008 08:09 AM -----



"Brenda Stein"

**<brenda@exdengineering.co
m>**

To Aaron Setran/R9/USEPA/US@EPA

cc

10/08/2008 10:23 PM

Subject RE: 081007 PTP EPA violation.pdf

Aaron,

Thank you for the opportunity to clarify this issue.

It is my understanding from Jim that there were complaints from the neighbors near the lower fields. The complaints stemmed from the odor. In an experimental move, he turned off those fields to give them a rest and try to alleviate the odor. Because of this, the upper fields were taking all the flow from the entire subdivision. We did determine that the weak link is field F5 which is adjacent to the disallowed area. We learned this field cannot be overloaded. We will have to address the odor issue down below in a way that will allow the lower fields to be utilized.

I hope this explains the reason for this situation. If you require additional information or if you need a more official letter, please let me know.

Brenda Stein P.E., M.B.A.
Principal Engineer
brenda@exdengineering.com

EXD Engineering & Land Surveying, Inc.
1641 Mono Avenue Minden, Nevada 89423
Ph: (775) 783-4772 Fx: (775) 783-4773

-----Original Message-----

From: Setran.Aaron@epamail.epa.gov [<mailto:Setran.Aaron@epamail.epa.gov>]
Sent: Wednesday, October 08, 2008 1:45 PM
To: Brenda Stein
Cc: Campbell.Rich@epamail.epa.gov
Subject: Re: 081007 PTP EPA violation.pdf

Brenda:

Thank you for the quick response. Your letter did not mention the reason(s) why Jim Robinson diverted all the wastewater to the upper leachfield. Could you please provide a response explaining the reasoning behind his decision to divert flows to this field. Thank you, Aaron

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

"Brenda Stein"
<brenda@exdengin
eering.com>

10/07/2008 10:39
PM

Aaron Setran/R9/USEPA/US@EPA

To

cc

Subject

081007 PTP EPA violation.pdf

(See attached file: P:\2006 Projects\PTP\081007 PTP EPA violation.pdf)

No virus found in this incoming message.

Checked by AVG - <http://www.avg.com>

Version: 8.0.173 / Virus Database: 270.7.6/1714 - Release Date: 10/8/2008 7:01 AM